


Chief, Real Estate & Construction  
2430 "E" Street, N. W.  
Washington 25, D. C.  
29 June 1953


25X1A9a



25X1A9a Dear Mr. [REDACTED]:

Regarding your inquiry, dated 24 June 1953, as to  
meaning of Paragraph 8.19 of Specifications, the tests in  
question should be made of each twenty-five (25) cubic  
yards of concrete.

Very truly yours,



25X1A9a

*P.S. All your personal mail has either  
been sent on and should either be in  
your hands or en route. Some printed  
matter was held pending receipt of your  
address.*

*Regards,*

*Cy*